



FOOTINGS: ALL BEARING FOOTINGS SHALL BEAR @ 18" (MIN) BELOW TOP OF UNDISTURBED SOIL OR TOP OF ENGINEER-CERTIFIED COMPACTED SOIL



EXTERIOR WALL FOOTING - CMU STEM

SCALE: NTS